



WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle)

☒ Construction☐ Decommission ORIGINAL INSTALLATION Notice of Intent Number _____

PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal
☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____
☒ New well ☐ Reconditioned ☐ Deepened
 Method: ☐ Dug ☐ Bored ☐ Driven
☒ Cable ☐ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 205 ft.
 Depth of completed well 204.5 ft.

CONSTRUCTION DETAILS
 Casing ☒ Welded 6 " Diam. from 71.5 ft. to 194.5 ft.
 Installed: ☐ Liner installed " Diam. from " ft. to " ft.
☐ Threaded " Diam. from " ft. to " ft.

Perforations: ☐ Yes ☒ No
 Type of perforator used _____
 SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: ☒ Yes ☐ No ☒ K-Pac Location 193.5
 Manufacturer's Name Johnson
 Type Stainless Model No. Tele
 Diam. 5 Slot size 15 from 194.5 ft. to 199.5 ft.
 Diam. 5 Slot size 15 from 199.5 ft. to 204.5 ft.

Gravel/Filter packed: ☐ Yes ☒ No ☐ Size of gravel/sand _____ ft.
 Materials placed from _____ ft. to _____ ft.

Surface Seal: ☒ Yes ☐ No To what depth? 18 ft.
 Material used in seal Bentonite
 Did any strata contain unusable water? ☐ Yes ☒ No
 Type of water? no Depth of strata _____
 Method of sealing strata off _____

PUMP: Manufacturer's Name _____
 Type: _____ H.P. _____

WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
 Static level 171 ft. below top of well Date 272
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)


| Time | Water Level | Time | Water Level | Time | Water Level |
|------|-------------|------|-------------|------|-------------|
| | | | | | |
| | | | | | |
| | | | | | |

 Date of test _____
 Bailer test 10 gal./min. with 2 ft. drawdown after 2 hrs.
 Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? ☐ Yes ☒ No

CURRENT

Notice of Intent No. W257519Unique Ecology Well ID Tag No. BAE 402

Water Right Permit No. _____

Property Owner Name WOODLAND ESTATESWell Street Address Woodland CircleCity Oak Harbor County ISLANDLocation NE1/4-1/4 SW1/4 Sec 1 Twn 33 R 1  circle one

Lat/Long (s, t, r) Lat Deg _____ Lat Min/Sec _____

Still REQUIRED) Long Deg _____ Long Min/Sec _____

Tax Parcel No. S8475-00-00042-2

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

| MATERIAL | FROM | TO |
|---------------------|------|-----|
| Brown Gravel | 0 | 8 |
| Comp Gravel | 8 | 46 |
| Clay | 46 | 51 |
| Silty sand | 51 | 92 |
| Sand Clean | 92 | 115 |
| Silty sand | 115 | 142 |
| Silty Sand & Gravel | 142 | 172 |
| Sand & Clay mix | 172 | 180 |
| Gravel with sand | 180 | 204 |

Well site approved by ISLAND County Health Dept

RECEIVED

MAY 06 2008

DEPT. OF ECOLOGY

Start Date 4/7/08 Completed Date 4/12/08

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee Name (Print) E Boonstra
 Driller/Engineer/Trainee Signature E Boonstra
 Driller or trainee License No. 0038

 Drilling Company WHIDBEY DRILLERS
 Address 716 Holbrook Rd
 City, State, Zip Coupeville WA 98239
 Contractor's
 Registration No. WHIDBWD94499 Date 4/14/08
 Ecology is an Equal Opportunity Employer.

 IF TRAINEE,
 Driller's Licensed No. _____
 Driller's Signature _____